

NOTES

1. ALL EQUIPMENT SHOWN ON THIS DRAWING IS LOCATED IN THE 1 WTC 41ST FLOOR MECHANICAL EQUIPMENT ROOM
2. CONTRACTOR SHALL VERIFY WITHIN MER EXACT LOCATION OF MCC'S AND STARTERS AND ROUTE WIRING ACCORDINGLY. PROVIDE 20% SPARES TO EACH MCC.

THE PORT AUTHORITY OF NY & NJ

ENGINEER OF DESIGN E.D.D., PORTS AND
WORLD TRADE

The A.E. All

CHIEF ELECTRICAL ENGINEER

Engineering Department				
Design Divisions				

**World
Trade
Center**

Title

TOWER M.E.R'S
SPRINKLER INSTALLATION
AND MODIFICATION
TO SMOKE DETECTION
SYSTEM

ELECTRICAL

SMOKE DETECTION PANEL
XL No. 5 RISER DIAGRAM

7-12-90 REV. ENCIRCLED AREA B.R. 12

No.	Date	Revision	Approved
-----	------	----------	----------

This drawing subject to conditions in contract.
All inventions, ideas, designs and methods
herein are reserved to Port Authority and
may not be used without it's written consent.

<u>DaCOSTA/ AVENOSO</u>	<u>AVENOSO</u>	<u>PALANGO</u>
Designed by	Drawn by	Task Leader

Checked by M. K. K. K. K.

Date 5-15-90 Scale NONE

Contract Number Drawing Number

WTC 499.18 E-8

